



FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

Member of the FM Global Group

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

8146/5. Control & Distribution Panel per 81 461 15 00 0.

I / 1 / AEx d e IIC / T5...T6; S / I / 2 / ABCD / T5...T6; Type 3, 4, 4X, IP66

Special Conditions of Use:

1. *The circuit breaker access panels may only be opened briefly for operation of the circuit breakers and then re-closed in accordance with the instructions 81 466 39 30 0.*

Equipment Ratings:

Class I, Zone 1, AEx d e IIC T5...T6
Class I, Division 2, Group ABCD
Ta = -20°C to +40°C
Type 3, 4, 4X, IP66

FM Approved for:

R. Stahl Schaltgeraete GmbH
D-74638 Waldenburg, GERMANY



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
ANSI/UL 508	2005
UL 508A	2001
ANSI/ISA 60079-0	2002
ANSI/ISA 60079-1	2002
ANSI/ISA 60079-7	2002
NEMA 250	1991
ANSI/IEC 60529	2004


Original Project ID: 3031420

Approval Granted: *July 7, 2009*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC



 Robert L. Martell, Jr.
 Assistant Vice President

July 7, 2009

 Date