

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

8146/5. Control & Distribution Panel per 81 461 15 00 0. I / 1 / Ex d e IIC / T5...T6; Type 3, 4, 4X, IP66

Special Conditions of Use:

1. The circuit breaker access panels may only be opened briefly for operation of the circuit breakers and then reclosed in accordance with the instructions 81 466 39 30 0.

Equipment Ratings:

Ex d e IIC T5...T6 Ta = -20°C to +40°C Type 3, 4, 4X, IP66

FM Approved for:

R. Stahl Schaltgeraete GmbH D-74638 Waldenburg, GERMANY



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

CSA - C22.2 No. 14	2005
CSA - C22.2 No. 94	1991
CSA C22.2 No. 60529	2005
CAN/CSA E60079-0	2002
CAN/CSA E60079-1	2002
CAN/CSA E60079-7	2003

Original Project ID: 3031420C

Approval Granted: July 7, 2009

Subsequent Revision Reports / Date Approval Amended

Report Number

Date

Report Number

Date

FM Approvals LLC

Robert L. Martell, Jr.

Assistant Vice President

1/47, 3009