

QUZW.E81680 - Process Control Equipment for Use in Hazardous Locations

Process Control Equipment for Use in Hazardous Locations

R. STAHL Schaltgeraete GmbH

Am Bahnhof 30

Waldenburg, 74638 Germany

E81680

Associated apparatus, Class I, Div. 2, Groups A, B, C and D, providing intrinsically safe circuits for use in Class I, Groups C and D; Class II, Groups E, F and G; Class III hazardous locations, installed according to Drawing 9000-3UL, 9000-4UL Model(s) Shunt diode barrier combinations

Associated apparatus, Class I, Div. 2, Groups A, B, C and D, shunt diode barriers Model(s) 9001/a-280-280-101, 9001/b-308-230-101, providing intrinsically safe circuits for use in Class I, Group D; Class II, Groups E, F and G; Class III, hazardous locations when installed in accordance with control drawing No. 90 016 11 31 3. (a)

Associated apparatus, Class I, Div. 2, Groups A, B, C and D, shunt diode barriers, Type 9001 Model(s) 9001/51-280-091-141, 9001/a-168-100-101, 9001/b-061-020-101, 9001/b-196-010-101, 9001/51-280-110-141, 9001/a-199-010-101, 9001/b-061-050-101, 9001/b-196-020-101, 9001/a-050-050-101, 9001/a-199-020-101, 9001/b-061-150-101, 9001/b-196-030-101, 9001/a-050-100-101, 9001/a-199-038-101, 9001/b-093-003-101, 9001/b-196-050-101, 9001/a-050-150-101, 9001/a-199-050-101, 9001/b-093-020-101, 9001/b-196-075-101, 9001/a-083-442-101, 9001/a-199-070-101, 9001/b-093-030-101, 9001/b-196-100-101, 9001/a-086-010-101, 9001/a-199-100-101, 9001/b-093-050-101, 9001/b-196-120-101, 9001/a-086-020-101, 9001/a-199-150-101, 9001/b-093-075-101, 9001/b-196-125-101, 9001/a-086-050-101, 9001/a-199-270-101, 9001/b-093-100-101, 9001/b-196-150-101, 9001/a-086-075-101, 9001/a-252-057-141, 9001/b-093-120-101, 9001/b-224-020-101, providing intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; Class III, hazardous locations when installed in accordance with control drawing Nos. 90 016 11 31 3 or 90 026 11 31 3. (a)

Associated apparatus, Class I, Div. 2, Groups A, B, C and D, shunt diode barriers, Type 9001 Model(s) 9001/a-086-075-101, 9001/a-252-060-141, 9001/b-093-150-101, 9001/b-224-050-101, 9001/a-086-100-101, 9001/a-252-070-101, 9001/b-093-250-101, 9001/b-224-075-101, 9001/a-086-150-101, 9001/a-252-100-141, 9001/b-093-270-101, 9001/b-224-100-101, 9001/a-086-270-101, 9001/a-280-020-101, 9001/b-093-390-101, 9001/b-224-120-101, 9001/a-086-390-101, 9001/a-280-050-101, 9001/b-133-003-101, 9001/b-224-150-101, 9001/a-126-020-101, 9001/a-280-075-101, 9001/b-133-020-101, 9001/b-280-015-101, 9001/a-126-050-101, 9001/a-280-085-101, 9001/b-133-050-101, 9001/b-280-020-101, 9001/a-126-075-101, 9001/a-280-100-101, 9001/b-133-075-101, 9001/b-280-050-101, 9001/a-126-100-101, 9001/a-280-110-101, 9001/b-133-100-101, 9001/b-280-075-101, providing intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; Class III, hazardous locations when installed in accordance with control drawing Nos. 90 016 11 31 3 or 90 026 11 31 3. (a)

Associated apparatus, Class I, Div. 2, Groups A, B, C and D, shunt diode barriers, Type 9001 Model(s) 9001/a-126-140-101, 9001/a-315-020-101, 9001/b-133-120-101, 9001/b-280-090-101, 9001/a-126-150-101, 9001/a-315-050-101, 9001/b-133-150-101, 9001/b-280-120-101, 9001/a-137-065-101, 9001/a-315-070-101, 9001/b-172-270-101, 9001/b-307-075-101, 9001/a-158-005-101, 9001/a-398-020-101, 9001/b-172-390-101, 9001/b-412-040-101, 9001/a-158-150-101, 9001/a-398-050-101, 9001/b-175-020-101, 9001/c-086-000-101, 9001/a-158-270-101, 9001/b-016-015-101, 9001/b-175-050-101, 9001/c-168-000-101, 9001/a-158-390-101, 9001/b-016-050-101, 9001/b-175-075-101, 9001/c-199-000-101, 9001/a-168-007-101, 9001/b-016-050-111, 9001/b-175-100-101, 9001/c-280-000-101, 9001/a-168-020-101, 9001/b-016-150-101, 9001/b-175-120-101, 9001/a-168-050-101, 9001/b-016-150-111, 9001/b-175-150-101, 9001/a-168-075-101, 9001/b-016-320-101, 9001/b-175-200-101, providing intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; Class III, hazardous locations when installed in accordance with control drawing Nos. 90 016 11 31 3 or 90 026 11 31 3. (a)

Associated apparatus, Class I, Div. 2, Groups A, B, C and D, shunt diode barriers, Type 9001 Model(s) 9001/a-199-390-101, 9001/a-280-165-101, 9001/b-217-270-101, 9001/b-217-390-101, 9001/b-307-130-101, 9001/b-412-065-101, 9001/b-412-095-101, providing intrinsically safe circuits for use in Class I, Groups C and D; Class II, Groups E, F and G; Class III, hazardous locations when installed in accordance with control drawing Nos. 90 016 11 31 3 or 90 026 11 31 3. (a)

Associated apparatus, Class I, Div. 2, Groups A, B, C and D, shunt diode barriers, Type 9002 Model(s) 9002/00-120-024-001, 9002/11-199-030-001, 9002/13-280-100-041, 9002/33-280-000-001, 9002/00-260-138-001, 9002/11-260-138-001, 9002/13-280-110-001, 9002/34-280-000-001, 9002/10-187-020-001, 9002/11-280-112-001, 9002/22-016-383-111, 9002/77-093-040-001, 9002/10-187-270-001, 9002/11-280-293-001, 9002/22-032-300-111, 9002/77-093-300-001, 9002/10-210-030-001, 9002/11-280-293-021, 9002/22-048-442-111, 9002/77-100-400-001, 9002/11-120-024-001, 9002/13-199-225-001, 9002/22-158-200-001, 9002/77-150-300-001, 9002/11-130-360-001, 9002/13-252-121-041, 9002/22-240-024-001, 9002/77-220-146-001, 9002/11-137-029-001, 9002/13-280-093-001, 9002/22-240-160-001, 9002/77-280-094-001, providing intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; Class III, hazardous locations when installed in accordance with control drawing Nos. 90 016 11 31 3 or 90 026 11 31 3.

Associated apparatus, Class I, Div. 2, Groups A, B, C and D, shunt diode barriers, Type 9002 Model(s) 9002/00-280-186-001, 9002/77-220-296-001, 9002/11-280-186-001, 9002/11-280-244-001, 9002/13-280-188-001, providing intrinsically safe circuits for use in Class I, Groups C and D; Class II, Groups E, F and G; Class III, hazardous locations when installed in accordance with control drawing Nos. 90 016 11 31 3 or 90 026 11 31 3.

Associated Apparatus, non-hazardous locations or Class I, Division 2, Groups A, B C and D, open type interface modules Model(s) 9276/10-21-60-11k, 9276/10-21-60-11s

Associated Apparatus, non-hazardous locations or Class I, Division 2, Groups A, B C and D, open type interface modules, for use in Class I, Division 2 Groups A, B, C and D Model(s) 9199/20-04

Associated apparatus, nonhazardous locations, digital outputs Model(s) 9175, followed by /1 or /2, followed by 0, followed by -1, followed by 2, 4 or 6, followed by -11, providing intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; and Class III Hazardous Locations when installed per control drawing No. 91 756 01 31 3.

Associated apparatus, nonhazardous locations, digital outputs loop powered Model(s) 9176, followed by /1 or /2, followed by 0, followed by -1, followed by 2, 4, 5, or 6, followed by -00, providing intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; and Class III Hazardous Locations when installed per control drawing No. 91 766 01 31 3.

Associated apparatus, nonhazardous locations, I.S. relay modules Model(s) 9172, followed by /1 or /2, followed by 0 or 1, followed by -11, followed by -00, providing intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; and Class III Hazardous Locations when installed per control drawing No. 91 726 01 31 3.

Associated apparatus, nonhazardous locations, isolating repeater HART inputs Model(s) 9163, followed by /1 or /2, followed by 3, followed by -1, followed by 0 or 1, followed by -11, providing intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; and Class III Hazardous Locations when installed per control drawing No. 91 636 01 31 3.

Associated apparatus, nonhazardous locations, isolating repeaters Model(s) 9165, followed by /1 or /2, followed by 1 or 6, followed by -11, followed by -1, followed by 1 or 3, providing intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; and Class III Hazardous Locations when installed per control drawing No. 91 656 01 31 3.

Associated apparatus, nonhazardous locations, isolating repeaters loop powered Model(s) 9167, followed by /1 or /2, followed by 1, 3 or 4, followed by -11, followed by -00, providing intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; and Class III Hazardous Locations when installed per control drawing No. 91 676 01 31 3.

Associated apparatus, nonhazardous locations, switching repeaters Model(s) 9170, followed by /1 or /2, followed by 0, followed by -1, -2, -3, -4 or -5, followed by 0, 1, 2, 3 or 4, followed by -1 or -2, followed by 1, providing intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; and Class III Hazardous Locations when installed per control drawing No. 91 706 01 31 3.

Associated apparatus, nonhazardous locations, temperature transmitters Model(s) 9182, followed by /1 or /2, followed by 0, followed by -5, followed by 0, 1, 3 or 9, followed by -1, followed by 1 or 2, providing intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; and Class III Hazardous Locations when installed per control drawing No. 91 826 01 31 3.

Associated apparatus, nonhazardous locations, transmitter supply units Model(s) 9160, followed by /1 or /2, followed by 1, 3 or 9, followed by -1, followed by 0 or 1, followed by -11, providing intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; and Class III Hazardous Locations when installed per control drawing No. 91 606 01 31 3.

Class I, Division 1, Groups A, B, C and D, intrinsically safe LED indicator lights, when installed in accordance with control drawing No. 80 136 01 31 3 Model(s) 8013/32

Class I, Division 1, Groups A, B, C and D, pilot lights, per drawing No. 80 186 01 31 3 Model(s) 8018/32, followed by 1, 2, or 3; followed by 3, followed by additional suffixes.

Class I, Division 2, Groups A, B, C and D Open type, associated apparatus Model(s) 9265/16-11-10k provide intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D, Class II, Division 1, Groups E, F and G, and Class III, Division 1 Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9265 6 031 001 3.

Class I, Division 2, Groups A, B, C and D Open type, associated apparatus Model(s) 9265/16-11-10s provide intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D, Class II, Division 1, Groups E, F and G, and Class III, Division 1 Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9265 6 031 001 3.

Class I, Division 2, Groups A, B, C and D Open type, associated apparatus Model(s) 9265/26-11-10k provide intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D, Class II, Division 1, Groups E, F and G, and Class III, Division 1 Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9265 6 031 001 3.

Class I, Division 2, Groups A, B, C and D Open type, associated apparatus Model(s) 9265/26-11-10s provide intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D, Class II, Division 1, Groups E, F and G, and Class III, Division 1 Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9265 6 031 001 3.

Class I, Division 2, Groups A, B, C and D Open type, associated apparatus Model(s) 9282/11-51-16k provide intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D, Class II, Division 1, Groups E, F and G, and Class III, Division 1 Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9282 6 031 001 3.

Class I, Division 2, Groups A, B, C and D Open type, associated apparatus Model(s) 9282/11-51-16s provide intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D, Class II, Division 1, Groups E, F and G, and Class III, Division 1 Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9282 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9275/10-21-25-11k provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9275 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9275/10-21-25-11s provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9275 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9275/10-24-48-11k provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9275 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9275/10-24-48-11s provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9275 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9276/10-21-25-00k provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9276 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9276/10-21-25-00s provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9276 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9276/10-21-40-00k provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9276 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9276/10-21-40-00s provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9276 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9276/10-21-60-00k provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9276 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9276/10-21-60-00s provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9276 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9276/10-24-48-00k provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9276 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9276/10-24-48-00s provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9276 6 031 001 3.

(a) - Where a = 00 (negative polarity) or 01 (positive polarity), b = 02 (nonpolarized, AC), c = 03 (Diode return type, positive polarity) or 04 (Diode return type, negative polarity).

Trademark and/or Tradename: 

Last Updated on 2021-08-26

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2021 UL LLC"

QUZW7.E81680 - Process Control Equipment for Use in Hazardous Locations Certified for Canada

Process Control Equipment for Use in Hazardous Locations Certified for Canada

R. STAHL Schaltgeraete GmbH

Am Bahnhof 30

Waldenburg, 74638 Germany

E81680

Associated Apparatus, non-hazardous locations or Class I, Division 2, Groups A, B C and D, open type interface modules Model(s) 9276/10-21-60-11k, 9276/10-21-60-11s

Associated Apparatus, non-hazardous locations or Class I, Division 2, Groups A, B C and D, open type interface modules, for use in Class I, Division 2 Groups A, B, C and D Model(s) 9199/20-04

Class I, Division 1, Groups A, B, C and D, intrinsically safe LED indicator lights, when installed in accordance with control drawing No. 80 136 01 31 3 Model(s) 8013/32

Class I, Division 1, Groups A, B, C and D, pilot lights, per drawing No. 80 186 01 31 3 Model(s) 8018/32, followed by 1, 2, or 3; followed by 3, followed by additional suffixes.

Class I, Division 2, Groups A, B, C and D Open type, associated apparatus Model(s) 9265/16-11-10k provide intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D, Class II, Division 1, Groups E, F and G, and Class III, Division 1 Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9265 6 031 001 3.

Class I, Division 2, Groups A, B, C and D Open type, associated apparatus Model(s) 9265/16-11-10s provide intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D, Class II, Division 1, Groups E, F and G, and Class III, Division 1 Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9265 6 031 001 3.

Class I, Division 2, Groups A, B, C and D Open type, associated apparatus Model(s) 9265/26-11-10k provide intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D, Class II, Division 1, Groups E, F and G, and Class III, Division 1 Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9265 6 031 001 3.

Class I, Division 2, Groups A, B, C and D Open type, associated apparatus Model(s) 9265/26-11-10s provide intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D, Class II, Division 1, Groups E, F and G, and Class III, Division 1 Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9265 6 031 001 3.

Class I, Division 2, Groups A, B, C and D Open type, associated apparatus Model(s) 9282/11-51-16k provide intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D, Class II, Division 1, Groups E, F and G, and Class III, Division 1 Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9282 6 031 001 3.

Class I, Division 2, Groups A, B, C and D Open type, associated apparatus Model(s) 9282/11-51-16s provide intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D, Class II, Division 1, Groups E, F and G, and Class III, Division 1 Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9282 6 031 001 3.

Class I, Division 2, Groups A, B, C and D Open type, associated apparatus Model(s) 9282/12-51-16k provide intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D, Class II, Division 1, Groups E, F and G, and Class III, Division 1 Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9282 6 031 001 3.

Class I, Division 2, Groups A, B, C and D Open type, associated apparatus Model(s) 9282/12-51-16s provide intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D, Class II, Division 1, Groups E, F and G, and Class III, Division 1 Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9282 6 031 001 3.

Unclassified Associated apparatus "Switching Repeater" Model(s) 9170 , followed by /1 or /2, followed by 1, followed by -1, followed 0, 1, 2, or 3, followed by -2, followed by 1, providing intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed per control drawing No. 91 706 03 31 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9260/13-11-10k provides intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9260 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9276/10-21-25-00k provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9276 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9276/10-21-25-00s provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9276 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9276/10-21-40-00k provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9276 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9276/10-21-40-00s provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9276 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9276/10-21-60-00k provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9276 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9276/10-21-60-00s provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9276 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9276/10-24-48-00k provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9276 6 031 001 3.

Unclassified Associated apparatus, open type interface modules Model(s) 9276/10-24-48-00s provide intrinsically safe circuits for use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. 9276 6 031 001 3.

Trademark and/or Tradename: 

Last Updated on 2021-08-26

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2021 UL LLC"