

1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

Type 8162/1 Breathing Gland
Type 8162/9 Breathing Gland

Equipment Ratings:

Increased Safety AEx e II for Class I, Zone 1, Group II
Suitable for Class I, Division 2, Groups A,B,C,&D
Enclosure Type 3R, IP54

Approved for:

R. STAHL SCHALTGERAETE GMBH
D-74638 Waldenburg, GERMANY

Factory Mutual Research

This certifies that the equipment described has been found to comply with the following Factory Mutual Research Approval Standards and other documents:

Class 3600	1998
ANSI/NEMA 250	1991
IEC 60529	1989

Original Approval Job Identification: 3000248 Approval Granted: June 18, 1998

Subsequent Revision Reports / Date Approval Amended

3011878 August 6, 2001

Factory Mutual Research Corporation



P Stavrianidis
Assistant Vice President
Approvals Division

August 13, 2001
Date