



# 中国国家强制性产品认证证书



证书编号: 2020322310002415

认证委托人名称: R. STAHL Schaltgeräte GmbH  
 认证委托人地址: Am Bahnhof 30, 74638, Waldenburg, Germany  
 生产者名称: R. STAHL Schaltgeräte GmbH  
 生产者地址: Am Bahnhof 30, 74638, Waldenburg, Germany  
 生产企业名称: R. STAHL Schaltgeräte GmbH  
 生产企业地址: Am Bahnhof 30, 74638, Waldenburg, Germany  
 产品名称: 总线导轨  
 系列、规格、型号: 9494/a-bc  
 标准: GB/T 3836.1-2021、GB/T 3836.4-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。产品相关信息详见附件。

发证日期: 2023年03月31日

有效期至: 2025年09月27日

首次发证日期: 2020年09月28日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



批准:



## 上海仪器仪表自控系统检验测试所有限公司

<http://www.sitiias.com.cn>

中国·上海·漕宝路103号200233

电话: +86 21 64510844

S 0009074



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322310002415

**APPLICANT:** R.STAHL Schaltgeräte GmbH  
**ADDRESS:** Am Bahnhof 30, 74638, Waldenburg, Germany  
**MANUFACTURER:** R.STAHL Schaltgeräte GmbH  
**ADDRESS:** Am Bahnhof 30, 74638, Waldenburg, Germany  
**FACTORY:** R.STAHL Schaltgeräte GmbH  
**ADDRESS:** Am Bahnhof 30, 74638, Waldenburg, Germany

**PRODUCT:** BusRail  
**SERIES,SPECIFICATION,MODEL:** 9494/a-bc  
**STANDARDS:** GB/T 3836.1-2021、GB/T 3836.4-2021

**Type of Certification:** Type test + Initial inspection + Surveillance inspection

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019). Refer to the attachment for detailed information.

**Valid from:** March 31, 2023

**Valid until:** September 27, 2025

**Date of original certification:** September 28, 2020

**The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.**

This certificate is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



APPROVAL:

Guo AiHua



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**

<http://www.sitias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0007130



# 中国国家强制性产品认证证书



证书编号：2020322310002415

## 附 件

产品名称：总线导轨

型号规格：9494/a-bc

a: A1, S1, L1;

b: B, E, M, V;

c: 0, 1-4, 6-9。

防爆标志：Ex ia IIC T4 Gb

电气参数：

接口	插针	安全参数
V003, V005, V007, V009	7, 8, 9, 10 (+) 27, 28, 29, 30 (-)	$U_i=26.2V$
V001, V002	7, 8, 15, 16 (+) 1, 2, 9, 10 (-)	$U_i=26.2V$
V003, V005, V007, V009	4, 5, 14, 15, 16, 24	$U_i=6.6V$
V001, V002	13, 5, 12, 3, 11, 4	$U_i=6.6V$

相关报告编号：2023S17402-010907、2020S17402-001577

使用条件：

特殊（限制）使用条件：

1. 产品使用环境温度范围为-40℃~+75℃。
2. 本产品须安装于外壳防污染等级为2级的壳体中。
3. 本产品须安装于符合国家标准 GB/T 3836.1-2021 规定的、外壳防护等级不低于 IP54 的外壳中，方可用于爆炸性危险场所。

批 准：



## 上海仪器仪表自控系统检验测试所有限公司



# 中国国家强制性产品认证证书



**SITIAs**  
Worldwide Access

证书编号: 2020322310002415

## 附 件

4. 只有经过认证的远程 I/O 系统, 型号为 IS1/IS1+, 可以连接到本产品上。
5. DIN 导轨或接地件应可靠连接至地电位平衡系统。

批 准:



上海仪器仪表自控系统检验测试所有限公司