



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312308000116

Applicant	R. STAHL Schaltgeräte GmbH
Address	Am Bahnhof 30, 74638 Waldenburg, Germany
Manufacturer	R. STAHL Schaltgeräte GmbH
Address	Am Bahnhof 30, 74638 Waldenburg, Germany
Production Factory	R. STAHL Schaltgeräte GmbH
Production Address	Am Bahnhof 30, 74638 Waldenburg, Germany
Product	Plug
Model/Type	8571/*2-***-*(-*)
Ex marking	Ex eb IIC T6/T5 Gb, Ex tb IIIC T81°C Db
Reference Standards	GB/T 3836.1-2021, GB/T 3836.3-2021, GB/T 3836.31-2021

Certification mode Type Test + Initial Factory Inspection + Post-Certification Surveillance

The sample(s) is verified and certified according to CNCA-C23-01: 2019 *China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product* and CNEX-C2301-2019 *Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product*.

See Annex for the detailed product information (5 pages).

Initial issue date: 2022-02-12

Issued date: 2023-04-24

Valid to: 2027-02-11

The Validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the Original Chinese version, the Chinese version shall prevail.

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China
Tel: 0377-63239734

P.C.: 473008

Email: ccc@cn-ex.com

CN 0001960



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312308000116

Page 1 of 5

Product information:

1. This certificate covers the following models:

- 8571/*2-***-*(-*)

Nomenclature:

8571	/	*	*	-	*	**	-	*	(-*)
a	/	b	c	-	d	e	-	f	g

a: Type series

b: Design:

1 = Standard

2 = North America

c: Device:

2 = Plug

d: Poles:

4 = 3P + PE

5 = 3P + N + PE

e: Position for earth contact and voltage / frequency / colour

f: Sealing material:

B = silicone free

S = containing silicone

g: Denotes any number or character (Not affecting Ex performance)

Ambient temperature:

For Plug type 8571/*2-***-*(-*) with sealing ring made of D0122-01:

-40°C ≤ Tamb ≤ +40°C ... 65°C / T6 ... T5 by current range 16 A...32A

Issued date: 2023-04-24

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China
Tel: 0377-63239734

P.C.: 473008

Email: ccc@cn-ex.com



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312308000116

Page 2 of 5

For Plug type 8571/*2-***-*(-*) with sealing ring made of D0123-01:
 $-50^{\circ}\text{C} \leq T_{\text{amb}} \leq +40^{\circ}\text{C} \dots 65^{\circ}\text{C} / T_6 \dots T_5$ by current range 16 A...32A

Service temperature:

For Plug type 8571/*2-***-*(-*) with sealing ring made of D0122-01:
 $-40^{\circ}\text{C} \leq T_s \leq +75^{\circ}\text{C}$ (for the enclosure and cable gland)

$-40^{\circ}\text{C} \leq T_s \leq +95^{\circ}\text{C}$ (for terminals)

For Plug type 8571/*2-***-*(-*) with sealing ring made of D0123-01:
 $-50^{\circ}\text{C} \leq T_s \leq +75^{\circ}\text{C}$ (for the enclosure and cable gland)

$-50^{\circ}\text{C} \leq T_s \leq +95^{\circ}\text{C}$ (for terminals)

Electrical Data:

	Main contacts
	4, 5 poles
Max. rated operational voltage	690V AC/110V DC
Max. rated insulation voltage	750V AC
Max. rated operational current	32A
Rated frequency	0-500Hz
Short-circuit protection	35A gG
Terminal capacity for plug type 8571/*2-**	1 x 2.5-10mm ² (12...8AWG) stranded
PE conductor size	Max.10mm ²
Tightening torque	Terminals: max.1.2Nm Terminal compartment cover: max.1.0Nm

Issued date: 2023-04-24

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312308000116

Page 3 of 5

	Cable gland screw: 0.5Nm Cable strain relief: 1.5Nm
Clamping range of cable gland	13 up to 25 mm
Cable entries (of the Plug)	13 up to 25 mm Ring 1 + 2 + 3 + 4 +5: 13 up to 16 mm Ring 2 + 3 + 4 +5: 16 up to 19 mm Ring 3 + 4 +5: 19 up to 22 mm Ring 4 +5: 22 up to 25 mm

Note: Stranded wires are suitable with or without wire end ferrules.

Ingress protection: IP64

(The plug shall be free from water and dust before is inserted to the flange socket.)

Ex marking: Ex eb IIC T6/T5 Gb, Ex tb IIIC T81°C Db

- Producers should organize production in accordance with the technical documents approved by the certification body.

2. Specific conditions of safety use:

- In order to ensure the ingress protection IP, the bayonet ring of the plug must be screwed up to the stop to the socket.
- The plug shall be free from water and dust before is inserted to the socket.
- The connecting cable of the plug type 8571/**-***-* shall be fixed and routed so that it will be adequately protected against mechanical damage.
- The tensile test according to Annex A of the standard GB/T3836.1 was performed with cable of different sizes according to the manufacturer. The

Issued date: 2023-04-24

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312308000116

Page 4 of 5

approved cable sizes that can be used for the plug are listed in the electrical data.

- If the temperature at the input parts exceeds 70°C, temperature-resistant connecting cables shall be used.
- Installation of electrical components requires a further assessment by an ExCB.
- The plug must not be used in dust areas where highly charge-generating processes, machine friction and separation processes, electron spraying (e.g. around electrostatic coating systems) and pneumatically conveyed dust occur.
- The user shall be informed of the following conditions in an appropriate form, e.g. with a note included in the operating instructions:
 - WARNING – THE PLUG SHALL BE FREE FROM WATER AND DUST BEFORE IS INSERTED TO THE SOCKET.
 - WARNING – DO NOT OPEN WHEN ENERGIZED.
 - WARNING – POTENTIAL ELECTROSTATIC CHARGING HAZARD – SEE INSTRUCTIONS
 - WARNING – THE PLUG SHALL BE FIRMLY MOUNTED AT THE SOCKET IN ORDER TO ENSURE THE INGRESS PROTECTION IP
 - WARNING – TEMPERATURE AT THE ENTRY POINTS HIGHER THAN +70°C. A PROPER SELECTION OF CABLE AND CABLE GLANDS OR CONDUCTORS IN CONDUIT IS REQUIRED
- See instruction for other information.

3. Certificate related report(s):

- Type test report: CQST2112C004, CQST2112C004/01
- Factory inspection report: CN2022Q030187

4. Certificate change information:

Issued date: 2023-04-24

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312308000116

Page 5 of 5

- 1st change on April 24, 2023:

- (1) Updated the standards for certification.
- (2) Changing the model form 8571/*2-***-* to 8571/*2-***-*(-*).

Issued date: 2023-04-24

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China
Tel: 0377-63239734

P.C.: 473008

Email: ccc@cn-ex.com